

Memo No:- 2405

Date:- 28/07/2023

Subject : **Physical / Chemical Examination Report of Water Sample**

Sample ID/Classification : KNL/02212/7/2023 / Private		Sample Details	Date & Time
Sender :	PRINCIPAL APOLLO INTERNATIONAL SCHOOL23676	Collected By	
Location :	, village Dadupur, Nilokheri, KARNAL HARYANA	Collection Date	28/07/2023 at 09:38
Sample Description :	Drinking Water	Received at lab	28/07/2023 at 10:07
Latitude / Longitude :	76.968441 / 29.766851	Analysis Start Date	28/07/2023
		Analysis End Date	28/07/2023
		Sample Quantity	1000ML

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	150	500 mg/lit.	2000 mg/lit.	IS 3025 (Part-16) : 1984 (RA 2017)
2	Total Hardness as CaCo <sub>3</sub>	100	200 mg/lit.	600 mg/lit.	IS 3025 (Part-21) : 2009 (RA 2019)
3	Calcium as Ca	20	75 mg/lit.	200 mg/lit.	IS 3025 (Part-40) : 1991 (RA 2019)
4	Magnesium as Mg	12	30 mg/lit.	100 mg/lit.	IS 3025 (Part-46) : 1994 (RA 2019)
5	Iron as Fe	0.01	1.0 mg/lit.	1.0 mg/lit.	USEPA-8008:2017
6	Chloride as Cl	36	250 mg/lit.	1000 mg/lit.	IS 3025 (Part-32) : 1988 (RA 2019)
7	Sulphate as So <sub>4</sub>	15	200 mg/lit.	400 mg/lit.	USEPA-8051:2017
8	Fluoride as F	0.210	1.0 mg/lit.	1.5 mg/lit.	APHA 4500-F--C
9	Nitrate as No <sub>3</sub>	1.5	45 mg/lit.	45 mg/lit.	APHA 4500-NO <sub>3</sub> - D
10	pH @ 25°C	7.45	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 1983 (RA 2017)
11	Total Alkalinity	110	200 mg/lit.	600 mg/lit.	IS 3025 (Part-23) : 1986 (RA 2019)
12	Color	< 5.0	5 Hazen Units	15 Hazen Units	IS 3025 (Part-4) : 1983 (RA 2017)
13	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
14	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 1984 (RA 2017)
15	Turbidity	<1.0	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2017)

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

-----END OF TEST REPORT-----





**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**STATE WATER TESTING LABORATORY ,KARNAL**

Website :- <https://phedharyana.gov.in/>



Certificate  
No: TC-8407

Memo No:- 2405

Date:- 28/07/2023

Subject : **Physical / Chemical Examination Report of Water Sample**



Sample analyzed by :

AMIT KUMAR ,CHIEF CHEMIST  
STATE WATER TESTING LABORATORY,KARNAL  
email:-chiefchemist.hr@phedharyana.gov.in